

Checklist: Test reports of airtightness measurements

- Is all general information included?
 - Tester: name, address and signature
 - Object
 - Date of test
 - Device
 - Measurement standard (norm)
 - Inside and outdoor temperatures
 - Wind velocity
 - Flow coefficient C_{env}
 - Leakage coefficient C_L

- Is the airtightness measurement performed in accordance with EN 13829 (Method A) or alternatively in accordance with ISO 9972 (Method 1 or 3)?

- Is room-by-room calculation of the air volume of the building included? Is the calculation correct?

- Has the installation location of the fan been documented?

- Has temporary sealing of the building envelope been recorded (sealing of outdoor air and exhaust air ducts at least)?

- Has a series of measurements at excess pressure AND negative pressure been performed?

- For each series of measurements, were 5 measuring points used at different pressure differences (highest value ± 50 Pa at least)?

- Is the flow exponent "n" between 0.5 and 1.0 (otherwise indicates measurement error due to a change in the envelope e.g. window opening)?

- Is the average value of the natural pressure difference between -5 and 5 Pa (measurement of the pressure difference before and after each measurement series)?
Note: If the wind speed is greater than 6 m/s (21.6 km/h) OR the wind force is higher than 3 Beaufort, the stated limiting values for the pressure difference will usually be exceeded.

Recommendation: leakage detection at negative pressure should be carried out before the measurements, and any large leaks should be rectified and this should be documented.

Exception: For the measurement of tall buildings (e.g. high-rise buildings) special boundary conditions apply. Please contact your certifier or building.certification@passiv.de