

## Checklist: Ventilation System

### Ventilation system:

- Controllability: At least 3 **operation modes** ('boost' +30%, standard, basic - 30%)?
- Are **all rooms ventilated**, either by means of SUP, ETA or transfer air (also utility rooms, mechanical room itself etc.)?
- Excessively low relative indoor air humidity (< 30%)? Countermeasures taken?
- Sound level?
- Draughts?

### Ventilation unit:

- Accessibility for maintenance** checked?: Filters, condensate pan and drain, heat exchanger, summer bypass
- Structure-borne sound decoupling** of the ventilation unit?
- Are **silencers planned** for SUP and ETA, possibly ODA and EHA?
- Condensate drain with double siphon** connected to drain pipe (check slope and filling level of siphons)?
- Is **frost protection temperature** for pre-heating set to the point considered in the energy balance calculation (PHPP)?
- If subject to frost (**outside installation**): Condensate drain heated and insulated?
- Intermittent operation: **Filter drying** before switching off fans possible?

### Filters:

- ODA filter (at least F7): correctly mounted (check fit and air flow direction)?
- ETA filter (F7/F8): correctly mounted (check fit and air flow direction)?
- Do "pre-filter" and "grease filter"(kitchen) **correctly fit** in ETA?
- Accessibility and maintainability** of the filters possible?



### Outdoor air (ODA) and Exhaust air (EHA):

- ODA intake:** Clean air (at least 3 m above ground, air pollution, odour sources)?; Protected from manipulation, rain, snow?
- Avoid „short-circuiting“** between EHA and ODA (odours, direction of flow, distance)
- Don't direct **EHA outlets** at building assemblies (risk of condensation).
- Outside wall penetrations:** vapour tight? Thermally insulated? Connected to the airtight layer?
- Unit within thermal envelope:** ODA and EHA ducts insulated up to the insulation layer of the thermal envelope with at least 50 mm, thermal bridge free and vapour tight? Short duct length?
- Unit outside thermal envelope:** SUP and ETA ducts insulated up to the thermal envelope with at least 50 mm and thermal bridge free? Short duct length?
- ODA and EHA valves **accessible for cleaning and inspection**?
- Intermittent operation: Airtight ODA and EHA valves installed?
- ODA and EHA air volume flow calibrated and imbalance lower than 10%?  
*Information to be filled in the [commissioning report](#)*

### Supply air (SUP) and extract (ETA) air ducts:

- Structure-borne sound decoupling** of the ventilation ducts?
- Are **supply air heating ducts** sufficiently insulated?
- Are **supply air cooling ducts** sufficiently insulated and vapour tight?
- Do the ventilation ducts have a smooth interior surface?
- Duct system with minimal pressure loss? Duct crossing avoided?
- Are SUP and ETA ducts equipped with **cross-talk silencers**?

### Supply (SUP), extract (ETA) and transfer air valves:

- SUP and ETA air volume flows are **adjusted as planned** for each room?  
*Information to be filled in the [commissioning report](#).*



- Are the SUP and ETA valves and their **adjustment documented**? *Information to be filled in the [commissioning report](#).*
- Jet nozzles** mounted approx. 15 cm below ceiling (from the middle of the jet)?
- Are the **openings for air transfer planned** in all designated rooms (e.g. 1.5 cm door gap) (pressure loss of max. 1 Pa, check by measuring the air flow velocity (< 1m/s))? *Information to be filled in the [commissioning report](#).*

#### **Additional components:**

- Kitchen hood planned with recirculation air**?
- Kitchen hood planned with exhaust to outside**? Additional supply air flow available? [Not recommended for Passive Houses!](#)
- Safety equipment checked for **combined operation with a wood stove** (if applicable)?
- Supply air heating coil** tested (max. supply air temperature 52 °C, avoid dust smouldering).
- Room temperature adjustable independently from SUP air flow rate?

#### **Fire protection:**

- Fire and smoke safety dampers clean and operation checked?

#### **Inspection of the subsoil heat exchanger:**

- Check ductwork for leaks (pressure test).
- Check duct system for sloping (no unwanted basins)?
- Drainage (condensate) by means of a double siphon.
- Ensure accessibility (cleaning).